



**BUILDING AND SAFETY  
11600 AIR EXPRESSWAY  
ADELANTO, CA 92301**

## **SMOKE AND CARBON MONOXIDE DETECTORS REQUIRED**

I, the undersigned, hereby certify that I am the owner and occupant of the below referenced property. I further certify that smoke alarms and carbon monoxide alarms are present and functional in ALL the following locations: (As of January 1, 2014, all smoke alarms must be equipped with non-replaceable and non-removable batteries.)

- ☐ Smoke Detectors: In each sleeping room. Outside of each separate sleeping area in the immediate vicinity of the bedroom(s). On each additional story of the dwelling, including basements and habitable attics but not including crawl spaces and uninhabitable attics. In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level
- ☐ Carbon Monoxide Detectors: Outside of each separate dwelling unit sleeping area in the immediate vicinity of bedroom(s). On every level of a dwelling unit including basements. When a permit is issued for any existing sleeping unit with a fossil fuel burning heater or appliance, fireplace or an attached garage.

Owners Name: \_\_\_\_\_  
(Print Clearly)

Permit # \_\_\_\_\_

Dwelling Address \_\_\_\_\_

Owners

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

California Residential Code (CRC) Section R314.3.1 & R314.3.2 in part states: "When a permit is required for new and existing dwellings, smoke alarms are to be installed and shall be tested, maintained and replace (that no longer function.) Smoke detectors shall be replaced after (10) years from the date of manufacture marked on the unit or if the date of manufacture cannot be determined." CRC Carbon Monoxide Sections R315.2.3.1 & R315.2.3 in part states: "On or after July 1, 2011, carbon monoxide alarms shall be installed in accordance with Section R315.2 and on or after January 1, 2013, carbon monoxide alarms shall be installed with Section R315.2 in all other existing dwelling units intended for human occupancy as defined in Health and Safety code Section 132629(b). CRC Smoke Alarm Section R314.3 and CRC Carbon Monoxide Section R315.2 & R315.2.6 defines required location as indicated above.

**NOTE: The CRC requires carbon monoxide and smoke alarms in dwellings when building permits are issued and the scope of the work exceeds a total cost or calculated valuation of \$1,000. In order to grant a final approval on your permit, it is necessary to verify the installation of these alarms within your dwelling. This form provides the ability to self-verify to Building & Safety when work done does not allow convenient access to the interior of the dwelling (i.e., re-roof, patio covers, swimming pools or other exterior work.)**